



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, South 24 Parganas**  
**West Bengal Fire & Emergency Services**  
**6, Diamond Harbour Road, Silpara, Kol-700008**

Memo no.: IND/WB/FES/ 20182019/17035

Date: 14-08-2023

**From:**

**Divisional Fire Officer, South 24 Parganas**  
**West Bengal Fire & Emergency Services**

**To: Annie Besant Day School**

**Mouza-Mohanpur, Vill.-Parulia, P.S.-Diamond Harbour, Dist.-South 24 Parganas, Pin-743368**

**Sub: Renewal of Fire Safety Certificate (part) for a G+I storied under group Educational Building at the premises No.-Mouza-Mohanpur, Vill.-Parulia, P.S.-Diamond Harbour, Dist.-South 24 Parganas, Pin-743368.**

This is in reference to your application no. 0125191231200262 dated 07-08-2023 regarding the Renewal of Fire Safety Certificate (part) for a G+I storied under group Educational Building at the premises No.-Mouza-Mohanpur, Vill.-Parulia, P.S.-Diamond Harbour, Dist.-South 24 Parganas, Pin-743368.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

1. Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the driveway.
2. The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.
3. To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling.
5. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
6. The employees and security staff shall be conversant with installed Firefighting equipment's of the building and to operate in the event of Fire and testing.

7. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
8. Electrical switch gear room shall be protected with automatic CO2 or D.C.P Fire extinguisher confirming I.S. specification.
9. First aid Fire fighting system shall be provided as per I.S. specification.
10. Arrangement shall have to be made for regular checking, testing and maintenance of all the Firefighting installation in the building to keep them in perfectly good working condition at all the times.
11. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.
12. Periodical flashing of water from the fire water pipe line shall be made to maintain efficient working performance of above mentioned system.
13. This Renewal of Fire Safety Certificate is valid for 03(Three) years from the date of issue of this certificate.
14. Renewal of Fire Safety Certificate is to be obtained from the Divisional Fire Officer, West Bengal Fire & Emergency Services, for performances of all the Life and Fire Safety arrangements and installation of the building.

Signature valid

Digitally Signed.  
Name: TARUN KUMAR JUTTA  
Date: 14-Aug-2023 10:23  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, South 24 Parganas  
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FESI/20182019/17055